



MATERIALS		
ITEM	QUANTITY	DESCRIPTION
1	1	ROMAC STYLE 306 STAINLESS STEEL SERVICE SADDLE
2		2-INCH, TYPE 316 STAINLESS STEEL PIPE (LENGTH AS NEEDED)
3	1	2-INCH, STAINLESS STEEL GATE VALVE
4	1	VENT-O-MAT, 2-INCH, AIR RELEASE VALVE, MODEL 050RGX0521, WITH 3/4-INCH NPT
5	1	WATER PLUS CORP ENCLOSURE, MODEL 131632 (GREEN)
6	1	2-INCH BALL VALVE, FORD B44-777 COMPRESSION JOINT BOTH ENDS
7	2	DIELECTRIC UNION
8	1	2-INCH, STAINLESS STEEL BALL VALV, FULL PORT
9		2-INCH, PET SDR-9, POLYETHYLENE TUBING (LENGTH AS NEEDED)
10	2	2-INCH x 90° BEND, STAINLESS STEEL
11	2	STRAIGHT BRASS PACK JOINT COMPRESSION COUPLING, FORD C84-77

CITY OF PALM BAY, UTILITIES DEPARTMENT
POLICIES, PROCEDURES AND STANDARDS
INSTALLATION DETAIL

**AIR RELEASE VALVE DETAIL
WITH VENT OFFSET**

DWN.BY: M.K.L. DATE: 1-1-08
REV. M.K.L. DWG. NO.
02-03-11 **FIG 11B**